



# **Perform Basic Fire Fighting**

## **Handout 3**

# **Weekly Fire Extinguisher Checklist**

**WEEKLY FIRE EXTINGUISHER CHECKLIST**

ID No	FIRE EXTINGUISHERS	Yes	No	Yes	No	Yes	No	Yes	No	COMMENTS
	Equipment due for service.									
	Corroded or damaged.									
	Label missing or damaged.									
	Damaged symbolic signs.									
	Unit correctly located.									
	Wrong type fire extinguisher									
	Equipment obstructed or inaccessible.									
	Seal missing or broken.									
	Hose / nozzle missing or damaged.									
	Pressure low gauge upright.									
	Other.									
	Are air horns in place									
	<b>HOSE REELS</b>									
	Due for annual service.									
	Corroded or damaged.									

	Label missing or damaged.									
	No or damaged symbolic signs.									
	Incomplete. Nozzle/stop valve/run-out guide.									
	Hose through run-out guide and sealed.									
	Reel obstructed or inaccessible.									
	Used for non-fire activities.									
	Not rolled up.									
	Other.									
	<b>Date Inspected:</b>									
	<b>Inspected by:</b>									
	<b>Spot Check (HSE Department):</b>									